

**MassDEP Drinking Water Program One Winter Street - 5th floor, Boston, MA 02108 Attention: School Lead and Copper  
Or [Program.Director-dwp@state.ma.us](mailto:Program.Director-dwp@state.ma.us) Subject line: School Lead and copper**

**Summary of results and actions taken by the school/facility**

City/Town: Ayer, MA  
School District or Owner: Ayer Shirley Regional School District


Name of school	Location of sample #	Lead results in mg/L	Copper Results in mg/L	ACTIONS TAKEN BY SCHOOL								
				Check <input type="checkbox"/> all applicable actions for each location in the columns below			Other Actions (Please specify below)					
				Notice provided to Students, Parents and Teachers (Provide date(s) of notice(s) and attach a copy)	Daily Flushing	Re-sample date	Re-sampled location is now below action level (Attach results)	Physically disconnected faucet from plumbing	Replaced plumbing and/or fixture	Posted notice on faucet to prevent drinking/cooking		
ASR High School	All locations											Took Samples for Water Quality Parameters at 4 locations to determine optimum corrosion control treatment
	All locations											Increased corrosion control chemical dose at Town Water Supplies
	PEAit #01	0.001	2.03	Y	Y			n/a	n/a	Y		
	Kitch #03	ND	2.41	Y	Y			n/a	n/a			Train Staff

	Kitch #05	ND	1.33		Y	Y		n/a	n/a		Train Staff
	M. Ent #10	ND	1.37		Y	Y		n/a	n/a	Y	
	Nurse ex. #15	ND	2.16		Y	Y		n/a	n/a		Train Staff
	FLLAC #16	ND	1.9		Y	Y		n/a	n/a		Train Staff
	Admin #17	0.002	1.82		Y	Y		n/a	n/a		Train Staff
	D wing #20	ND	1.54		Y	Y		n/a	n/a	Y	

Prepared by:  
 Robert Briggs, Facilities Supervisor  
 Mark Weitzel, Superintendent of Ayer Public Works

Date: 07/05/16

Principal Name: Albert Yarga  
 Superintendent Name: Dr. Mary Malone

Signature: 

Phone #: 978-772-8600 Ext 1683  
 E-mail Address: bob.briggs@astrsd.org